

ANALYTICAL REPORT

PREPARED FOR

Attn: Carol Deola
All Kids First Preschool
1385 Magnolia Road
Vineland, New Jersey 08361

Generated 7/20/2023 7:27:56 AM

JOB DESCRIPTION

All Kids First Preschool - Lead/Copper

JOB NUMBER

630-66032-1


Eurofins Environment Testing Philadelphia, LLC

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and will meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Environment Testing Philadelphia, LLC Project Manager.

Authorization



Generated
7/20/2023 7:27:56 AM

Authorized for release by
Erin Dougherty, Project Administrator
Erin.Dougherty@et.eurofinsus.com
(215)355-3900

Compliance Statement


Analytical test results meet all requirements of the associated regulatory program (e.g., NELAC (TNI), DoD, and ISO 17025) unless otherwise noted under the individual analysis. Data qualifiers are applied to note exceptions. Noncompliant quality control (QC) is further explained in narrative comments. QC data that exceed the upper limits and are associated with non-detect samples are qualified but no further narration is needed since the bias is high and does not change a non-detect result. Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

Coliform MCLs

· Based on the EPA primary drinking water standard MCL for total coliforms, a water supply is considered bacteriologically "SAFE" if no coliform bacteria are detected. To be considered "SAFE" your report should indicate "<1 cfu/100mL" or "NEG" for the coliform test. If you report indicates a positive result "POS" or a value greater than or equal to one, then your supply is "UNSAFE FOR DRINKING" contact your local health department.

Warranties, Terms, and Conditions

- Analyses for Field Parameters are performed by Eurofins Philadelphia field staff. Locations and certifications are identified on the Chain of Custody as follows:
 - ERF = field staff performs tests under NJ State certification #02015
 - VL = field staff performs tests under NJ State certification #06005
 - WG = field staff performs tests under NJ State certification #PA001
 - H = field staff performs tests under NJ NELAP certification #PA093, PA NELAP certification # 46-05499
- Test results meet all TNI or other applicable regulatory agency requirements, including holding times and preservation, unless otherwise indicated.
- The report shall not be reproduced, except in full, without the written consent of the laboratory
- All samples are collected as "grab" samples unless otherwise identified.
- Reported results related only to the samples as tested. Eurofins Philadelphia is not responsible for sample integrity unless sampling has been performed by a member of our staff.
- Eurofins Philadelphia is not responsible for sampling and/or testing omissions. Note that regulatory authorities may assess substantial fines for testing omissions. Please track your sample collection schedules and results on a regular basis (e.g. weekly, monthly, or quarterly) to ensure compliance.
- Eurofins' online data portal "TotalAccess" will provide you with real-time access to collection dates and testing results. Please contact Client Services for further information.
- The following personnel or their deputies have approved the results of the tests performed by Eurofins Philadelphia : Nicki Smith (Environmental Chemistry) and Jacqueline Gartner (Water Microbiology).



Case Narrative

Client: All Kids First Preschool
Project/Site: All Kids First Preschool - Lead/Copper

Job ID: 630-66032-1

Job ID: 630-66032-1

Laboratory: Eurofins Environment Testing Philadelphia, LLC

Narrative

**Job Narrative
630-66032-1**

Receipt

The samples were received on 7/10/2023 10:07 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 22.8°C

Metals

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Sample Summary

Job ID: 630-66032-1

Client: All Kids First Preschool
 Project/Site: All Kids First Preschool - Lead/Copper

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
630-66032-1	RM 1 - BLDG 1	Drinking Water	07/10/23 08:56	07/10/23 10:07
630-66032-2	RM 2 - BLDG 1	Drinking Water	07/10/23 08:54	07/10/23 10:07
630-66032-3	RM 3 - BLDG 1	Drinking Water	07/10/23 08:52	07/10/23 10:07
630-66032-4	RM 4 - BLDG 1	Drinking Water	07/10/23 09:12	07/10/23 10:07
630-66032-5	RM 5 - BLDG 1	Drinking Water	07/10/23 08:59	07/10/23 10:07
630-66032-6	RM 6 - BLDG 1	Drinking Water	07/10/23 09:01	07/10/23 10:07
630-66032-7	RM 7 - BLDG 1	Drinking Water	07/10/23 09:04	07/10/23 10:07
630-66032-8	RM 8 - BLDG 1	Drinking Water	07/10/23 09:08	07/10/23 10:07
630-66032-9	RM 9 - BLDG 2	Drinking Water	07/10/23 08:52	07/10/23 10:07
630-66032-10	RM 10 - BLDG 2	Drinking Water	07/10/23 08:54	07/10/23 10:07
630-66032-11	RM 11 - BLDG 2	Drinking Water	07/10/23 08:56	07/10/23 10:07
630-66032-12	RM 12 - BLDG 3	Drinking Water	07/09/23 06:48	07/10/23 10:07
630-66032-13	RM 13 - BLDG 3	Drinking Water	07/09/23 06:46	07/10/23 10:07
630-66032-14	RM 14 - BLDG 3	Drinking Water	07/09/23 06:44	07/10/23 10:07
630-66032-15	RM 15 - BLDG 3	Drinking Water	07/09/23 06:42	07/10/23 10:07
630-66032-16	RM 16 - BLDG 3	Drinking Water	07/09/23 06:40	07/10/23 10:07
630-66032-17	RM 17 - BLDG 3	Drinking Water	07/09/23 06:39	07/10/23 10:07
630-66032-18	RM 18 - BLDG 3	Drinking Water	07/09/23 06:35	07/10/23 10:07
630-66032-19	RM 19 - BLDG 3	Drinking Water	07/09/23 06:33	07/10/23 10:07
630-66032-20	TEACHER'S LOUNGE - BLDG 3	Drinking Water	07/09/23 06:30	07/10/23 10:07

Client Sample Results

Client: All Kids First Preschool
 Project/Site: All Kids First Preschool - Lead/Copper

Job ID: 630-66032-1

Client Sample ID: RM 1 - BLDG 1

Lab Sample ID: 630-66032-1

Date Collected: 07/10/23 08:56

Matrix: Drinking Water

Date Received: 07/10/23 10:07

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	31		10	2.3	ug/L		07/19/23 15:45	1	UCIG
Lead	ND		1.0	0.69	ug/L		07/19/23 15:45	1	UCIG

Client Sample ID: RM 2 - BLDG 1

Lab Sample ID: 630-66032-2

Date Collected: 07/10/23 08:54

Matrix: Drinking Water

Date Received: 07/10/23 10:07

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	9.1	J	10	2.3	ug/L		07/13/23 18:57	1	UCIG
Lead	ND		1.0	0.69	ug/L		07/13/23 18:57	1	UCIG

Client Sample ID: RM 3 - BLDG 1

Lab Sample ID: 630-66032-3

Date Collected: 07/10/23 08:52

Matrix: Drinking Water

Date Received: 07/10/23 10:07

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	72		10	2.3	ug/L		07/13/23 18:54	1	UCIG
Lead	1.8		1.0	0.69	ug/L		07/13/23 18:54	1	UCIG

Client Sample ID: RM 4 - BLDG 1

Lab Sample ID: 630-66032-4

Date Collected: 07/10/23 09:12

Matrix: Drinking Water

Date Received: 07/10/23 10:07

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	70		10	2.3	ug/L		07/13/23 19:43	1	UCIG
Lead	1.1		1.0	0.69	ug/L		07/13/23 19:43	1	UCIG

Client Sample ID: RM 5 - BLDG 1

Lab Sample ID: 630-66032-5

Date Collected: 07/10/23 08:59

Matrix: Drinking Water

Date Received: 07/10/23 10:07

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	4.1	J	10	2.3	ug/L		07/19/23 15:33	1	UCIG
Lead	ND		1.0	0.69	ug/L		07/19/23 15:33	1	UCIG

Client Sample ID: RM 6 - BLDG 1

Lab Sample ID: 630-66032-6

Date Collected: 07/10/23 09:01

Matrix: Drinking Water

Date Received: 07/10/23 10:07

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	13		10	2.3	ug/L		07/13/23 18:55	1	UCIG
Lead	ND		1.0	0.69	ug/L		07/13/23 18:55	1	UCIG

Client Sample Results

Client: All Kids First Preschool
 Project/Site: All Kids First Preschool - Lead/Copper

Job ID: 630-66032-1

Client Sample ID: RM 7 - BLDG 1

Lab Sample ID: 630-66032-7

Date Collected: 07/10/23 09:04

Matrix: Drinking Water

Date Received: 07/10/23 10:07

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	6.6	J	10	2.3	ug/L		07/13/23 18:52	1	UCIG
Lead	ND		1.0	0.69	ug/L		07/13/23 18:52	1	UCIG

Client Sample ID: RM 8 - BLDG 1

Lab Sample ID: 630-66032-8

Date Collected: 07/10/23 09:08

Matrix: Drinking Water

Date Received: 07/10/23 10:07

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	41		10	2.3	ug/L		07/19/23 15:49	1	UCIG
Lead	ND		1.0	0.69	ug/L		07/19/23 15:49	1	UCIG

Client Sample ID: RM 9 - BLDG 2

Lab Sample ID: 630-66032-9

Date Collected: 07/10/23 08:52

Matrix: Drinking Water

Date Received: 07/10/23 10:07

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	28		10	2.3	ug/L		07/19/23 15:43	1	UCIG
Lead	ND		1.0	0.69	ug/L		07/19/23 15:43	1	UCIG

Client Sample ID: RM 10 - BLDG 2

Lab Sample ID: 630-66032-10

Date Collected: 07/10/23 08:54

Matrix: Drinking Water

Date Received: 07/10/23 10:07

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	72		10	2.3	ug/L		07/19/23 15:47	1	UCIG
Lead	0.73	J	1.0	0.69	ug/L		07/19/23 15:47	1	UCIG

Client Sample ID: RM 11 - BLDG 2

Lab Sample ID: 630-66032-11

Date Collected: 07/10/23 08:56

Matrix: Drinking Water

Date Received: 07/10/23 10:07

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	16		10	2.3	ug/L		07/19/23 15:31	1	UCIG
Lead	1.2		1.0	0.69	ug/L		07/19/23 15:31	1	UCIG

Client Sample ID: RM 12 - BLDG 3

Lab Sample ID: 630-66032-12

Date Collected: 07/09/23 06:48

Matrix: Drinking Water

Date Received: 07/10/23 10:07

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	90		10	2.3	ug/L		07/13/23 18:36	1	UCIG
Lead	ND		1.0	0.69	ug/L		07/13/23 18:36	1	UCIG

Client Sample Results

Client: All Kids First Preschool
 Project/Site: All Kids First Preschool - Lead/Copper

Job ID: 630-66032-1

Client Sample ID: RM 13 - BLDG 3

Date Collected: 07/09/23 06:46
 Date Received: 07/10/23 10:07

Lab Sample ID: 630-66032-13

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	50		10	2.3	ug/L		07/13/23 19:01	1	UCIG
Lead	ND		1.0	0.69	ug/L		07/13/23 19:01	1	UCIG

Client Sample ID: RM 14 - BLDG 3

Date Collected: 07/09/23 06:44
 Date Received: 07/10/23 10:07

Lab Sample ID: 630-66032-14

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	92		10	2.3	ug/L		07/19/23 15:35	1	UCIG
Lead	1.2		1.0	0.69	ug/L		07/19/23 15:35	1	UCIG

Client Sample ID: RM 15 - BLDG 3

Date Collected: 07/09/23 06:42
 Date Received: 07/10/23 10:07

Lab Sample ID: 630-66032-15

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	35		10	2.3	ug/L		07/19/23 15:42	1	UCIG
Lead	ND		1.0	0.69	ug/L		07/19/23 15:42	1	UCIG

Client Sample ID: RM 16 - BLDG 3

Date Collected: 07/09/23 06:40
 Date Received: 07/10/23 10:07

Lab Sample ID: 630-66032-16

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	28		10	2.3	ug/L		07/13/23 19:04	1	UCIG
Lead	ND		1.0	0.69	ug/L		07/13/23 19:04	1	UCIG

Client Sample ID: RM 17 - BLDG 3

Date Collected: 07/09/23 06:39
 Date Received: 07/10/23 10:07

Lab Sample ID: 630-66032-17

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	63		10	2.3	ug/L		07/13/23 19:02	1	UCIG
Lead	1.2		1.0	0.69	ug/L		07/13/23 19:02	1	UCIG

Client Sample ID: RM 18 - BLDG 3

Date Collected: 07/09/23 06:35
 Date Received: 07/10/23 10:07

Lab Sample ID: 630-66032-18

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	3.5	J	10	2.3	ug/L		07/13/23 18:59	1	UCIG
Lead	ND		1.0	0.69	ug/L		07/13/23 18:59	1	UCIG

Client Sample Results

Client: All Kids First Preschool
Project/Site: All Kids First Preschool - Lead/Copper

Job ID: 630-66032-1

Client Sample ID: RM 19 - BLDG 3

Lab Sample ID: 630-66032-19

Date Collected: 07/09/23 06:33

Matrix: Drinking Water

Date Received: 07/10/23 10:07

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	3.8	J	10	2.3	ug/L		07/19/23 15:36	1	UCIG
Lead	ND		1.0	0.69	ug/L		07/19/23 15:36	1	UCIG

Client Sample ID: TEACHER'S LOUNGE - BLDG 3

Lab Sample ID: 630-66032-20

Date Collected: 07/09/23 06:30

Matrix: Drinking Water

Date Received: 07/10/23 10:07

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	73		10	2.3	ug/L		07/19/23 15:12	1	UCIG
Lead	ND		1.0	0.69	ug/L		07/19/23 15:12	1	UCIG

Action Limit Summary

Client: All Kids First Preschool
 Project/Site: All Kids First Preschool - Lead/Copper

Job ID: 630-66032-1

Client Sample ID: RM 1 - BLDG 1

Lab Sample ID: 630-66032-1

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Copper	31		ug/L	1349		10	200.8 Rev 5.4	Total/NA
Lead	ND		ug/L	15.4		1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: RM 2 - BLDG 1

Lab Sample ID: 630-66032-2

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Copper	9.1	J	ug/L	1349		10	200.8 Rev 5.4	Total/NA
Lead	ND		ug/L	15.4		1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: RM 3 - BLDG 1

Lab Sample ID: 630-66032-3

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Copper	72		ug/L	1349		10	200.8 Rev 5.4	Total/NA
Lead	1.8		ug/L	15.4		1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: RM 4 - BLDG 1

Lab Sample ID: 630-66032-4

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Copper	70		ug/L	1349		10	200.8 Rev 5.4	Total/NA
Lead	1.1		ug/L	15.4		1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: RM 5 - BLDG 1

Lab Sample ID: 630-66032-5

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Copper	4.1	J	ug/L	1349		10	200.8 Rev 5.4	Total/NA
Lead	ND		ug/L	15.4		1.0	200.8 Rev 5.4	Total/NA

Action Limit Summary

Client: All Kids First Preschool
 Project/Site: All Kids First Preschool - Lead/Copper

Job ID: 630-66032-1

Client Sample ID: RM 6 - BLDG 1

Lab Sample ID: 630-66032-6

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Copper	13		ug/L	1349		10	200.8 Rev 5.4	Total/NA
Lead	ND		ug/L	15.4		1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: RM 7 - BLDG 1

Lab Sample ID: 630-66032-7

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Copper	6.6	J	ug/L	1349		10	200.8 Rev 5.4	Total/NA
Lead	ND		ug/L	15.4		1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: RM 8 - BLDG 1

Lab Sample ID: 630-66032-8

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Copper	41		ug/L	1349		10	200.8 Rev 5.4	Total/NA
Lead	ND		ug/L	15.4		1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: RM 9 - BLDG 2

Lab Sample ID: 630-66032-9

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Copper	28		ug/L	1349		10	200.8 Rev 5.4	Total/NA
Lead	ND		ug/L	15.4		1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: RM 10 - BLDG 2

Lab Sample ID: 630-66032-10

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Copper	72		ug/L	1349		10	200.8 Rev 5.4	Total/NA
Lead	0.73	J	ug/L	15.4		1.0	200.8 Rev 5.4	Total/NA

Action Limit Summary

Client: All Kids First Preschool
 Project/Site: All Kids First Preschool - Lead/Copper

Job ID: 630-66032-1

Client Sample ID: RM 11 - BLDG 2

Lab Sample ID: 630-66032-11

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Copper	16		ug/L	1349		10	200.8 Rev 5.4	Total/NA
Lead	1.2		ug/L	15.4		1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: RM 12 - BLDG 3

Lab Sample ID: 630-66032-12

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Copper	90		ug/L	1349		10	200.8 Rev 5.4	Total/NA
Lead	ND		ug/L	15.4		1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: RM 13 - BLDG 3

Lab Sample ID: 630-66032-13

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Copper	50		ug/L	1349		10	200.8 Rev 5.4	Total/NA
Lead	ND		ug/L	15.4		1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: RM 14 - BLDG 3

Lab Sample ID: 630-66032-14

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Copper	92		ug/L	1349		10	200.8 Rev 5.4	Total/NA
Lead	1.2		ug/L	15.4		1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: RM 15 - BLDG 3

Lab Sample ID: 630-66032-15

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Copper	35		ug/L	1349		10	200.8 Rev 5.4	Total/NA
Lead	ND		ug/L	15.4		1.0	200.8 Rev 5.4	Total/NA

Action Limit Summary

Client: All Kids First Preschool
 Project/Site: All Kids First Preschool - Lead/Copper

Job ID: 630-66032-1

Client Sample ID: RM 16 - BLDG 3

Lab Sample ID: 630-66032-16

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Copper	28		ug/L	1349		10	200.8 Rev 5.4	Total/NA
Lead	ND		ug/L	15.4		1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: RM 17 - BLDG 3

Lab Sample ID: 630-66032-17

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Copper	63		ug/L	1349		10	200.8 Rev 5.4	Total/NA
Lead	1.2		ug/L	15.4		1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: RM 18 - BLDG 3

Lab Sample ID: 630-66032-18

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Copper	3.5	J	ug/L	1349		10	200.8 Rev 5.4	Total/NA
Lead	ND		ug/L	15.4		1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: RM 19 - BLDG 3

Lab Sample ID: 630-66032-19

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Copper	3.8	J	ug/L	1349		10	200.8 Rev 5.4	Total/NA
Lead	ND		ug/L	15.4		1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: TEACHER'S LOUNGE - BLDG 3

Lab Sample ID: 630-66032-20

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Copper	73		ug/L	1349		10	200.8 Rev 5.4	Total/NA
Lead	ND		ug/L	15.4		1.0	200.8 Rev 5.4	Total/NA

Accreditation/Certification and Definitions Summary

Client: All Kids First Preschool
 Project/Site: All Kids First Preschool - Lead/Copper

Job ID: 630-66032-1

Laboratory: Eurofins Lancaster Laboratories Environment Testing, LLC

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
New Jersey	NELAP	PA011	06-30-24

Qualifiers

Metals

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
α	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
1C	Result is from the primary column on a dual-column method.
2C	Result is from the confirmation column on a dual-column method.
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
MRL	Method Reporting Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
SDL	Sample Detection Limit
SDL	Sample Detection Limit
SDL	Sample Detection Limit
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Method Summary

Client: All Kids First Preschool
Project/Site: All Kids First Preschool - Lead/Copper

Job ID: 630-66032-1

Method	Method Description	Protocol	Laboratory
200.8 Rev 5.4	Metals (ICP/MS)	EPA	ELLE
Non-Digest Prep	Preparation, Non-Digested Aqueous Metals	EPA	ELLE

Protocol References:

EPA = US Environmental Protection Agency

Laboratory References:

ELLE = Eurofins Lancaster Laboratories Environment Testing, LLC, 2425 New Holland Pike, Lancaster, PA 17601, TEL (717)656-2300

Client Information (Sub Contract Lab)
 Lab P/N: 630-11144-1
 State of Origin: New Jersey
 Erin Doughterty@eurofins.com
 Accreditations Required (See Note): NELAP - New Jersey

Analysis Requested
 Preservation Codes:
 A - HCL
 B - NaOH
 C - Zn Acetate
 D - Nitric Acid
 E - NaHSO4
 F - MeOH
 G - Amchlor
 H - Ascorbic Acid
 I - Ice
 J - DI Water
 K - EDTA
 L - EDA
 Other:
 M - Hexane
 N - None
 O - AsNaO2
 P - Na2O4S
 Q - Na2SO3
 R - Na2S2O3
 S - H2SO4
 T - TSP Dodecylhydrate
 U - Acetone
 V - MCAA
 W - pH 4-5
 Y - Tritama
 Z - other (specify)

Sample Information
 Project Name: All Kids First Preschool - CUIPB
 Site: S50W#

Sample Identification - Client ID (Lab ID)	Sample Date	Sample Time	Sample Type (C=Comp, G=grab)	Preservation Code	Matrix (W=Water, O=Organic, S=Soil, A=Air)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	200.0/ML ND Prep (MDI Lead/Copper)	Total Number of Containers	Special Instructions/Note:
RM 1 - BLDG 1 (630-66032-1)	7/10/23	08:55 Eastern	Drinking Water		Drinking Water	X	X	X	1	
RM 2 - BLDG 1 (630-66032-2)	7/10/23	08:54 Eastern	Drinking Water		Drinking Water	X	X	X	1	
RM 3 - BLDG 1 (630-66032-3)	7/10/23	08:52 Eastern	Drinking Water		Drinking Water	X	X	X	1	
RM 4 - BLDG 1 (630-66032-4)	7/10/23	08:12 Eastern	Drinking Water		Drinking Water	X	X	X	1	
RM 5 - BLDG 1 (630-66032-5)	7/10/23	08:59 Eastern	Drinking Water		Drinking Water	X	X	X	1	
RM 6 - BLDG 1 (630-66032-6)	7/10/23	09:01 Eastern	Drinking Water		Drinking Water	X	X	X	1	
RM 7 - BLDG 1 (630-66032-7)	7/10/23	09:04 Eastern	Drinking Water		Drinking Water	X	X	X	1	
RM 8 - BLDG 1 (630-66032-8)	7/10/23	08:08 Eastern	Drinking Water		Drinking Water	X	X	X	1	
RM 9 - BLDG 2 (630-66032-9)	7/10/23	08:52 Eastern	Drinking Water		Drinking Water	X	X	X	1	

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
 Return To Client Disposal By Lab Archive For _____ Months

Special Instructions/OC Requirements:

Empty Kit Relinquished by:
 Date/Time: 7/10/23 19:50
 Company: EAC VC
 Received by: Cadlers, R-NC
 Date/Time: 7/10/23 19:50
 Company: EAC
 Relinquished by: [Signature]
 Date/Time: 7/10/23 19:34
 Company: EAC
 Relinquished by: [Signature]
 Date/Time: 7/10/23 19:34
 Company: EAC
 Cooler Temperature(s) °C and Other Remarks: 14.7

Primary Deliverable Rank: 1

Unconfirmed Deliverable Requested: I, II, III, IV, Other (specify)

CHAIN OF CUSTODY
 Page 3 of 3

Bill to/Report to (if different):
 Sampling Site Address (if different) Include State:
 P.O. No.:
 Quote #:
 e-mail:
 PWSID #:
 ANALYSIS REQUESTED: Pb/Cu

LAB USE ONLY:
 # Ascorbic/HCL Vials # HCl Vials
 # Na2S2O3
 # Na OH/Zn acetate pH
 # HNO3 pH
 # H2SO4 pH
 # NaOH pH
 # Unpreserved
 # HCl # NH4Cl # MeOH
 # # # DI Water

MATRIX CODES:
 DW: DRINKING WATER
 GW: GROUND WATER
 WW: WASTEWATER
 SO: SOIL
 SL: SLUDGE
 OIL: OIL
 SOL: NON SOIL SOLID
 MI: MISCELLANEOUS
 X: OTHER
 Field pH, Temp (°C), DO, Cl2, Cond. etc.

LAB FIELD ID	Collection Date	Military Time	GRAMB	COIMP	Matrix Code	Total	H	V	H	N	Z	U	B	A	A	C	T
Rm. 12 - Bldg. 3	7/9/23	6:48				1	2	0	1	3							
Rm. 13 - Bldg. 3		6:46				1											
Rm. 14 - Bldg. 3		6:44				1											
Rm. 15 - Bldg. 3		6:42				1											
Rm. 16 - Bldg. 3		6:40				1											
Rm. 17 - Bldg. 3		6:39				1											
Rm. 18 - Bldg. 3		6:35				1											
Rm. 19 - Bldg. 3		6:33				1											
Teacher's Lounge - Bldg. 3		6:30				1											

SAMPLED BY: (Name/Company) Client
TAT: STANDARD (10 DAY)
 Report Format: Standard NJ-RDD SRP-RDD
 Standard + QC Forms EDD


Field Parameters Analyzed By:
 Initials: _____ Date/Time: _____

DELIVERED BY CUSTOMER
 Rec'd Temp: 22.8 °C Initials: MPM loc: N Location: ✓
 COMMENTS:
 Hazardous: yes/no

Eurofins Environment Testing Philadelphia,

213 Witmer Road
 Horsham, PA 19044-0962
 Phone: 215-355-3900

Chain of Custody Record



Environment Testing

Client Information (Sub Contract Lab)		Sampler:	Lab PM:	Lab Tracking No(s):	COC No:						
Shipping/Receiving		Phone:	Dougherty, Erin		630-11144 2						
Company:		E-Mail:	Erin.Dougherty@et.eurofins.com	State of Origin:	Page 2 of 3						
Eurofins Lancaster Laboratories Environm		Accreditations Required (See note):		Job #:	630-66032-1						
Address:		Due Date Requested:	Preservation Codes:								
2425 New Holland Pike,		7/24/2023	A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - NaHSO4 F - MeOH G - Amchlor H - Ascorbic Acid I - Ice J - DI Water K - EDTA L - EDA Other:								
City:		TAT Requested (days):	M - Hexane N - None O - AsNaO2 P - Na2O4S Q - Na2SO3 R - Na2SO4 S - H2SO4 T - TSP Dodecahydrate U - Acetone V - MCAA W - pH 4-5 X - Trizma Z - other (specify)								
Lancaster		PO #:	Analysis Requested								
State, Zip		WO #:	Total Number of containers								
PA, 17601		Project #:	Field Filtered Sample (Yes or No)								
Phone:		63004448	Perform MMSD (Yes or No)								
717-556-2300(Tel)		SSOW#:	200.8/MTL_ND_Prep (MOD) Lead/Copper								
Email:			Special Instructions/Note:								
Project Name:											
All Kids First Preschool - CUJPB											
Site:											
Sample Identification - Client ID (Lab ID)	Sample Date	Sample Time	Sample Type (C=comp, G=grab)	Matrix (W=water, S=solid, O=soil, B=biomass, A=air)	Preservation Code	Field Filtered Sample (Yes or No)	Perform MMSD (Yes or No)	200.8/MTL_ND_Prep (MOD) Lead/Copper	Analysis Requested	Total Number of containers	Special Instructions/Note:
RM 10 - BLDG 2 (630-66032-10)	7/10/23	08:54	Eastern	Drinking Water		X		X		1	
RM 11 - BLDG 2 (630-66032-11)	7/10/23	08:56	Eastern	Drinking Water		X		X		1	
RM 12 - BLDG 3 (630-66032-12)	7/9/23	06:48	Eastern	Drinking Water		X		X		1	
RM 13 - BLDG 3 (630-66032-13)	7/9/23	06:46	Eastern	Drinking Water		X		X		1	
RM 14 - BLDG 3 (630-66032-14)	7/9/23	06:44	Eastern	Drinking Water		X		X		1	
RM 15 - BLDG 3 (630-66032-15)	7/9/23	06:42	Eastern	Drinking Water		X		X		1	
RM 16 - BLDG 3 (630-66032-16)	7/9/23	06:40	Eastern	Drinking Water		X		X		1	
RM 17 - BLDG 3 (630-66032-17)	7/9/23	06:39	Eastern	Drinking Water		X		X		1	
RM 18 - BLDG 3 (630-66032-18)	7/9/23	06:35	Eastern	Drinking Water		X		X		1	

Note: Since laboratory accreditations are subject to change, Eurofins Environment Testing Philadelphia, LLC places the ownership of method, analyte & accreditation compliance upon our subcontract laboratories. This sample shipment is forwarded under chain-of-custody. If the laboratory does not currently maintain accreditation in the State of Origin listed above for analysis/test/matrix being analyzed, the samples must be shipped back to the Eurofins Environment Testing Philadelphia, LLC laboratory or other instructions will be provided. Any changes to accreditation status should be brought to Eurofins Environment Testing Philadelphia, LLC attention immediately. If all requested accreditations are current to date, return the signed Chain of Custody attesting to said compliance to Eurofins Environment Testing Philadelphia, LLC.

Possible Hazard Identification

Unconfirmed

Deliverable Requested: I, II, III, IV, Other (specify) _____

Primary Deliverable Rank: 1

Empty Kit Relinquished by: _____ Date: _____

Relinquished by: *Math McGill* Date/Time: 7/10/23 14:50 Company: EAC VL

Relinquished by: _____ Date/Time: _____ Company: _____

Relinquished by: _____ Date/Time: _____ Company: _____

Custody Seal No.: *F-NC* Custody Seal Intact: Yes No

Received by: *Codlers R-NC* Date/Time: 7/10/23 14:50 Company: EAC

Received by: _____ Date/Time: _____ Company: _____

Received by: *Sal* Date/Time: 7/10/23 19:34 Company: EAC

Cooler Temperature(s) °C and Other Remarks: 14.7

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
 Return To Client Disposal By Lab Archive For _____ Months

Special Instructions/QC Requirements: